



DOC No. HTH/QF/7.8

HARYANA TEST HOUSE

& Consultancy Services

GOVT. RECOGNISED LABORATORY

50-C, Sector-25 Part-II, HUDA, PANIPAT-132 103 (HR.)

Contact : (Off.) 86077-70160, 0180-3510205 (Env.) 86077-70164, (BM) 86077-70166, (Food) 86077-70169

Web Site : www.haryanatesthouse.net, e-mail : haryanatesthousecs@gmail.com, info@haryanatesthouse.net



TC-7811

**Recognition / Approval : MoEF / FSSAI / BIS / ISO 9001, 14001, 45001 Certified Lab.**

TEST REPORT

Issued To: HOLY CHILD SCHOOL Near Golden Tulip Resorts, Morni Road, Panchkula (HR)	Report No. : HTH/WT/220513016 ULR No. : TC781122200001021F Party's Ref No. : Nil Booking Date : 13/05/2022 Period of Testing : 13/05/2022 To 18/05/2022 Reporting Date : 18/05/2022
--	--

Sample Description : Drinking Water Sample Type of Industry : Not Specified Date of sampling : NS Date of receipt of sample : 13/05/2022 Environmental Condition : Not Specified Sampling Reference Protocol : Not Specified	Sample Name : Drinking Water Sample Sample quantity : 2 Ltr. + 250 ml in sterilized bottle Sample Location : Not Specified Purpose of analysis : Monitoring Sampling Done by : Sample supplied by party
---	--

REFERENCE TO PROTOCOL : IS 10500:2012 (Amend 3, Feb 2021)

TEST RESULTS

S.N.	Parameter's	Unit's	Results	Acceptable Limit's	Permissible Limit's	Method of Analysis
.Discipline - Chemical , Group -Water						
Organoleptic and Physical Parameter's						
1	pH	--	7.56	6.5-8.5	No Relaxation	IS 3025 (P-11)-1983
2	Total Dissolved Solids (TDS)	mg/l	352.0	500 Max.	2000 Max.	IS 3025 (P-16)-1984
General parameters Concerning Substances undesirable in excessive amounts						
1	Total Hardness (as CaCO ₃)	mg/l	112.0	200 Max.	600 Max.	IS 3025 (P-21)2009
2	Calcium (as Ca)	mg/l	12.8	75.0	200.0	IS 3025 (P-40)1991
3	Magnesium (as Mg)	mg/l	19.48	30.0	100.0	IS 3025 (P-46)1994
4	Chloride (as Cl)	mg/l	10.0	250 Max.	1000 Max.	IS 3025 (P-32)1988
5	Sulphate (as SO ₄)	mg/l	22.5	200 Max.	400 Max.	IS 3025 (P-24)1986
6	Nitrate (as NO ₃)	mg/l	5.60	45.0	No Relaxation	IS 3025 (P-34):2021
7	Fluoride (as F)	mg/l	0.4	1.0	1.5	APHA-4500 F-
8	Total Alkalinity (as CaCO ₃)	mg/l	296.0	200 Max.	600 Max.	IS 3025 (P-23)1986
Discipline - Biological , Group - Water						
1	Coliform	Per 100 ml	Absent	Shall Not be Detectable	No Relaxation	IS:15185:2016
2	E.coli	Per 100 ml	Absent	Shall Not be Detectable	No Relaxation	IS:15185:2016

End of Report

Remarks : Analysed parameters of water sample confirms to IS 10500:2012 specification with respect to permissible limits for the above test parameters.

Reviewed by

18-5-22

 Nao Jyoti Gupta
 H.O.D. (Biological)

18-05-2022

Auth. Sign.
 Dt. 18/05/22
 Md. Asfak Ansari
 Sr. Manager (Env.)

HYGEINE CERTIFICATE

It is certified that inspection with regard to maintenance of Healthy Surroundings and Hygienic sanitation condition of Holy Child School , Morni Road, Panchkula (Haryana) was carried out. As per observation proper health and sanitation conditions have been found. The school has proper ventilation, facility for drinking water, garbage disposal and toilet facilities with hygienic conditions.

This Office has no objection if school is granted recognition/ affiliation.

This certificate is valid for one year from the date of issue w.e.f. 01/08/2022.


Dy. Civil Surgeon
Panchkula

No: HR/PKL/2022/370

Dated- 01/08/2022

To
The Principal
Holy Child School
Panchkula (Haryana)